

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

Solicitation W91248-06-B-0006, Firing Range Construction and Development, Ranges 9, 11, 13, 14, 23 & 36, Fort Campbell, Kentucky is amended as follows:

A. Question: Reference Sheet E-3 Range 11 Detail 4. Please clarify the 1 ½” RGS Conduit Requirement for this light fixture.

Answer: Detail 4, Sheet E-3 lists 1 ½” rigid galvanized steel (RGS). This is because of the ease of pulling wires through the conduit. Also, the 1 ½” size provides better impact and bending resistance if stray vehicles or moving equipment get to close.

B. Question: Reference Sheet E-4 Range 11 cable trench detail, our understanding per the site visit is that there would be not excavation work. Is this detail for the new floodlight poles only?

Answer: Sheet E-4 show a trench detail. It appears to be a generic depiction illustrating data cables in addition to electrical conduits. This detail pertains to any underground wiring outside the impact area such as wiring to the tower and power poles, etc.

C. Question: Target pit details show conduite entry blockout and data boxes. Please clarify.

Answer: The target coffin details show blockout locations for future addition and use of data boxes and cables. No conduits are planned to be installed under this contract. The only items going in the ground are the ground rods.

D. All other terms and conditions remain unchanged.

POC: Debbie Rapp, Phone: 270-798-0121

Fax: 270-798-7820

Email: debbie.rapp@campbell.army.mil